



UNS Electric, Inc. Rules and Regulations

Original Sheet No.: 910
Superseding: _____

SECTION 10 METER READING

A. Measuring of Service

1. All energy sold to Customers and all energy consumed by the Company – except that sold according to fixed charge schedules – will be measured by commercially acceptable measuring devices owned and maintained by the Company. This provision will not apply where it is impractical to install meters, such as street lighting or security lighting, or where otherwise authorized by the ACC.
2. When there is more than one meter at a location, the metering equipment will be so tagged or plainly marked as to indicate the circuit metered or metering equipment in accordance with subsection 3(C)(9).
3. The Company employs meter reading technology that records interval data used to calculate consumption.

B. Customer-Requested Rereads

1. The Company will, at the request of a Customer, reread that Customer's meter within ten (10) business days after that request by the Customer.
2. Any reread may be charged to the Customer, at a rate set forth as Fee No. 2 in the UNS Electric Statement of Charges, if the original reading was not in error.
3. When a reading is found to be in error, the Company will not charge the Customer for the reread.

C. Access to Customer Premises

The Company will at all times have the right of safe ingress to and egress from the Customer's premises at all reasonable hours for any purpose reasonably connected with the Company's property used in furnishing service and the exercise of any and all rights secured to it by law or these Rules.

D. Meter Testing and Maintenance

1. The Company will replace any meter found to be damaged or associated with an inquiry into its accuracy, whether initiated by the Customer or Company, and which has been in service for more than sixteen years. Replaced meters will be tested for accuracy and will be acceptable if found to have an error margin within plus or minus three percent ($\pm 3\%$).
2. The Company will file an annual report with the Commission summarizing the results of meter maintenance and testing program for that year. At a minimum, the report should include the following data:
 - a. Total number of meters tested at Company initiative or upon Customer request; and
 - b. Number of meters tested that were outside the acceptable error allowance of $\pm 3\%$.

Filed By: Dallas J. Dukes
Title: Vice President of Customer Experience,
Programs and Pricing
District: Entire Electric Service Area

Effective: February 1, 2024
Decision No. 79277
Rules and Regulations



UNS Electric, Inc.
Rules and Regulations

Original Sheet No.: 910-1
Superseding: _____

SECTION 10
METER READING
(continued)

E. Customer-Requested Meter Tests

1. The Company will test a meter upon Customer request and the Company will be authorized to charge the Customer for the meter test. The charge for the meter test is set forth as Fee No. 7 in the UNS Electric Statement of Charges. However, if the meter is found to be in error by more than three percent (3%), no meter testing fee will be charged to the Customer.

F. Demand

1. The Customer's demand may be measured by a demand meter, under all Rates involving billings based on demand, unless appropriate investigation or tests indicate that the Customer's demand will not be such as to require a demand meter for correct application of the Rate. In cases where billings under a Rate requiring determination of the Customer's demand must be made before a demand meter can be installed, these billings may be made on an estimated demand basis pending installation of the demand meter. Billings made on the basis of estimated demand; however, will be appropriately adjusted, if actual demand recorded after demand meter is installed is greater or less than those estimated demand.
2. Demand meters may be installed at any metering location if the nature of the Customer's equipment and operation indicates that a demand meter is required for correct application of the rate schedule.

G. Automated Meter Opt-Out

Residential Service Basic (ERRES) Customers may request meters that do not transmit data wirelessly and the Company will accommodate such requests to the extent practicable. For Customers who choose to not have an automated meter installed or wish to replace an automated meter with a non-transmitting meter, the Special Meter Reading Fee set forth as Fee No. 3 in the UNS Electric Statement of Charges will be a monthly recurring charge. The Automated Meter Opt-Out Set-Up Fee set forth as Fee No. 4 in the UNS Electric Statement of Charges will only apply to those Customers who request the removal of an automated meter.

Filed By: Dallas J. Dukes
Title: Vice President of Customer Experience,
Programs and Pricing
District: Entire Electric Service Area

Effective: February 1, 2024
Decision No. 79277
Rules and Regulations