UniSource Energy Services



Please Sign In

Bienvenidos

(Hablamos español)

Por Favor Registrese

For more information / Para más información: www.uesaz.com/rio-rico-to-harshaw



Generation

Transmission

UniSource Energy Services

Sub-Transmission and Distribution



UniSourceEnergy SERVICES



Section 2C

UniSource Energy Services

Patagonia

Harshaw Ro



Duquesne Rd

Lochiel

UniSource Energy Services

INTERACTIVE MAP STATION





See where you live in

relation to the project

UniSource Energy Services

SITING PROCESS



Public Outreach

PHASE 2: DATA INVENTORY

- Planned land uses
- Biological resources
- FCC licensed communication sites
- Sensitive receptors
- Designated scenic areas
- Historic and archaeological sites
- Comprehensive environmental data
- Constructability data
- Stakeholder and public input

PHASE 3: SUITABILITY ASSESSMENT

Refined





The Arizona Corporation Commission will consider several factors before approving a Certificate of Environmental Compatibility. These factors, used by UNS to analyze potential line routes, include:



Wildlife and plant life



Scenic areas, historic sites and archaeological sites and structures





Noise emission levels and interference with communication signals



Potential public recreational uses



Existing development plans



Engineering feasibility and challenges



Project costs and potential impacts on customer rates







UniSourceEnergy SERVICES

Suitability Factors







Scenic Areas and Historic/Archaeological Sites **Total Environment**

Existing Development Plans

Wildlife and Plant Life

Engineering Feasibility



Noise Emissions/ Communication Interference

Public/Stakeholder Input

Composite Suitability Models











Pole Characteristics

Type: Tubular weathering steel monopoles

Pole height: Typically 75-110 feet

Span length: 600-1,000 feet (distance between poles)



Poles per mile: 5-9 Structures

Right of way width: Up to 100 feet



A typical weathering steel monopole supporting a 138 kilovolt transmission line

UNDERGROUND TRANSMISSION

	TEMPORARY VISUAL IMPACT AND DISTURBANCE	 Continuous disturbance along right of way. Minimum 30' wide. Typical trench created for duct bank is 4' wide by 5'deep. Width and depth will increase with slope in terrain. Access roads adjacent to trench continuously for access. Vault excavation typically 30' long by 10' wide. Work area 75' by 75' for equipment. Located every ~4000' due to cable length. Linear earthwork including excavation, cutting, and benching of hills to install duct bank. Minimum of 3.5 acres of disturbance per mile. 	 Disturbance occurs at transminevery 500' to 700' for 138 kV. Temporary disturbance at pole 138 kV is 50' by 75'. Access roads only to pole location. Wire pulling sites typically 100. Minimal earthwork, mainly claright of way, and removal of a Minimum of 0.7 acres of disturbance.
	PERMANENT VISUAL IMPACT AND DISTURBANCE	 Right of way will need to be kept clear of large vegetation to prevent root damage. Access required to vaults for inspection. No infrastructure visible except for high visibility markers and vault manhole caps. Scar of earthwork will remain. 	 Right of way will need to be key maintain clearances to overhey. Access not required to all poles. Poles and wires will be visible steel to blend with surroundires.
	MAINTENANCE / OPERATIONS	 Crews require special training, none currently at UNS. Inspections require line to be out of service for worker safety. Annual outage for inspections, typically 1 to 2 days per vault/mile 5 year inspection would increase outage to 3-5 days per vault. Minimized risk of unplanned outage due to weather. In the event of cable failure, locating fault is difficult and can take specialized equipment. Once failure point is located, repair can take days to months depending on spare materials onsite. 	 Utilize existing UNS maintena Annual visual inspection does 2 hours/mile. Most maintenance can occur Higher risk of unplanned outa Locating failure points is performance hours; repairs can often be con
	IMPACT TO THE ENVIRONMENT	 Construction of duct bank has substantial environmental impacts. If environmentally/culturally sensitive areas exist, trenchless installation can be utilized. Length limited; significantly increases cost. Large impact to wildlife, water, & environment during construction. Less impact to wildlife, water, environmental after installation. Low wildfire risk along underground route. 	 Overhead lines can typically s sensitive areas. Lines are designed to mitigate Wildfire risk is low on overhea and vegetation management operational procedures in place

OVERHEAD TRANSMISSION



UniSourceEnergy SERVICES

- ission pole locations, typically
- le locations varies but typical at
- ations. Use of existing roads. 0' by 300'.
- learing of large vegetation along all vegetation at pole locations. urbance per mile.
- ept clear of large vegetation to ead conductors.
- es, but preferred for maintenance. . Standard poles are self-rusting ngs and limit visual impact.
- ance personnel and training. s not require outage, typically
- while line is energized.
- age due to weather.
- formed visually typically within ompleted within a day.
- span environmentally/culturally
- e risks to wildlife such as birds. ead lines with proper maintenance program. UNS has robust ace.



UNDERGROUND TRANSMISSION

	ELECTRIC & MAGNETIC FIELDS	 Electric fields from underground lines are negligible. Magnetic fields are generally higher than overhead lines directly above duct bank but decrease rapidly with distance. Values are typically negligible at edge of right of way. 	 Electric & Magnetic fields are fright of way. Values are typically negligible a
	TRANSMISSION COSTS	 Typically 6 to 12 times the cost of overhead but can be higher based on project constraints. Average 10 times. 	• About \$2-3M per mile of overl
	ENGINEERING AND OPERATIONS LIMITATIONS	 Underground cable and associated equipment life expectancy is approximately 50-60 years. Underground transmission lines typically experience higher line losses than overhead transmission lines. Underground transmission lines typically carry less power and require larger or multiple cables to carry similar power to overhead transmission lines. Typically underground lines are limited to approximately 20 miles due to operational impacts. Lines require long sweeping turns both vertically and horizontally which creates difficulty in hilly/mountainous environments. 	 Overhead transmission line ex Overhead transmission lines ty than underground transmissio Overhead transmission lines ca underground transmission line No length limit to overhead tra Can be installed in difficult terr the environment.
	CONSTRUCTION CHALLENGES	 Vegetation clearing required along right-of-way. Large amount of grading and excavation required. Jack and bore or horizontal directional drilling installations may be required for environmental and road crossings which are impactful to surrounding environment. Road or lane closures common for routes along highways. Could restrict access to homes for periods of time. Presence of rock or hard soils can increase time and effort and have significant cost impacts. 	 Vegetation clearing required a Construction along roads could control during day. Subsurface conditions such as installation time.

OVERHEAD TRANSMISSION



UniSource Energy Services

found within transmission

at edge of right of way.

rhead transmission line.

xpected life range is over 80 years. ypically experience less line loss on lines.

can carry more power than es.

ransmission lines.

rrain without significant impact to

along right-of-way. Id require lane closure and traffic

rock has minimal impact on



UniSource Energy Services

An electric magnetic field is an invisible force field that occurs naturally (e.g., lightning and the Earth's magnetic field), and also as a byproduct of technology. Electric magnetic fields surround any electrical device, such as appliances, house wiring, and power lines. They are emitted by electrically powered systems that light, cool and heat our homes, provide our communications and entertainment, and support other aspects of our modern lifestyle. The transmission, distribution and use of electric power results in weak electric and magnetic fields.

Comparing the magnetic field levels of appliances to electric transmission and distribution lines, you can see that many common household items produce a higher field than an electric power transmission and distribution system.



EMFs weaken significantly as they extend away from the source. TEP designs and builds its equipment to meet or exceed national building and safety standards. Median magnetic field strength, measured in milliGauss (mG), for common household items and overhead power lines is shown in the chart below.



Scientists continue to research health risks from electromagnetic fields and radiation from high voltage power lines (EMF/EMR). It is understood that the greater the distance and the less time you spend near the source, the lower your exposure. Based on research to date, given the distance to the powerlines within their 50- to 100-footwide rights-of-way, EMF/EMR exposure of 138kV line from a nearby residence would be very low, comparable to appliances in your home, or even less.